



Ajadika
Amrit Mahotsav

Tel: 08192-258101
E-mail: dfodavanagere.ksfes@ka.gov.in



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/CC/SCI/33/DFO/DVG/2024

Date:30/03/2024

To

The Dean
Bapuji Higher Primary English School
MCC 'B' block
Davanagere city
Davanager Tq
Davanagere District

Sir,

Sub: Issue of Compliance Certificate to "Bapuji Higher Primary English School"
Situated Door no 33058, 1/A, MCC 'B' Block , Davanager City , Davanager Tq,
Davanagere District

Ref: 1) The district Fire Officer, davanagere Office Fire Safety Recommendation
C.No:20/FSR/SCI/33/DFO/DVG/2024 Date:26/03/2024
2) Your letter dated: 28/03/2024

>>>><<<<

With reference to subject cited above, Fire Safety Recommendation letter was issued vide reference (1) to "Bapuji Higher Primary English School" Situated Door no 33058, 1/A, MCC 'B', Block Davanager City ,Davanager Tq, Davanagere District with a condition to fulfill the recommendations and compliance the same.


With reference cited (2) above, The Dean , "Bapuji Higher Primary English School" Situated Door no 33058, 1/A, MCC 'B' Block , Davanager City , Davanager Tq, Davanagere District had requested for issue of the fire safety compliance report from our department. In this regard the building was inspected by me on 30/03/2024 to issue compliance Certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance report" to "Bapuji Higher Primary English School" Situated Door no 33058, 1/A, MCC 'B' Block , Davanager City , Davanager Tq, Davanagere District subject to proper maintenance of fire fighting installations in good working condition and impart 40% of employees should be trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or the Regional fire officer, davanagere range, davanagere fire station premises, davanagere within 90 days from the date of issue of this report.

This fire safety compliance certificate is valid till dated 29/03/2025 and it is renewable

J. P. Dhanu

PRINCIPAL
Bapuji Higher Primary English
School, MCC. 'B' Block,
DAVANAGERE-577 004.



Yours faithfully

[Signature] 30/3/24
District Fire Officer
Karnataka Fire & Emergency Service
Davanagere District



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/FSR/SCI/33/DFO/DVG/2024

Date:26/03/2024

To

The Dean
Bapuji higher primary English school
MCC "B"
Davanagere city
Davanagere Tq
Davanagere District

Sir,


Sub: Issue of 'Fire Safety Recommendation' to "Bapuji higher primary English school" door no : 33058, 1/A, MCC "B" ,Davanagere city, Davanagere Tq , Davanagere District

Ref: 1.Applicant Application Date: 28/02/2024
2. GBC(2)044/2020-21 Date:21-06-2022


With reference to the subject above, the premises to "Bapuji higher primary English school" door no : 33058, 1/A, MCC "B" ,Davanagere city, Davanagere Tq , Davanagere District was inspected me on 04/03/2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

| Sl No. | Details | Observation |
|--------|------------------------------------|--|
| 01. | Name and Address of the Applicant. | The Dean Bapuji higher primary English school MCC "B" Davanagere city Davanagere Tq Davanagere District |
| 02. | Name and Address of the premises. | Bapuji higher primary English school door no : 33058, 1/A MCC "B" Davanagere city Davanagere Tq |




| | | | |
|-----|--------------------------------------|---|--|
| | | | Davanagere District |
| 03. | Name & address of the building owner | : | The Dean Bapuji higher primary English school MCC "B" Davanagere city Davanagere Tq Davanagere District |
| 04. | Number of buildings | : | 02 Building , Building -1 :Ground +02 upper floors only Building -2 :Ground +03 upper floors only |
| 05. | Occupancy details of ground Floor | : | |
| | Building -1 | | |
| | Ground floor | | Office room, principal chamber, arts activity room, store room, 02 sports room, meeting hall, 08 class rooms, in charge room |
| | First floor | | 14 class rooms,03 staff room, computer lab, library, in charge room, sick room, dean room, robotic lab |
| | Second floor | | 16 class rooms, 03 staff rooms, computer lab |
| | Building -2 | | |
| | Ground floor | | Staff room, library , 4 class rooms, principal chamber |
| | First floor | | 05 class room, physics , biology & chemistry labs, 02 staff room |
| | Second floor | | 06 class room, computer lab, 02 staff room |
| | Third floor | | 06 class rooms, 02 staff room, dean room |
| 06 | Height of the building | : | Building -1 : 11.10 mtrs Building -2 : 14.85 mtrs |
| 07 | Site Area. | : | 6979.08 Sqmtrs |
| 08 | Built up area | : | |
| | Building -1 | | |
| | Ground floor | | 1388.97 Sq mtrs |
| | First floor | | 1388.97 Sq mtrs |
| | Second floor | : | 1388.97 Sq mtrs |
| | Total built up area | | 4166.91 Sqmtrs |
| | Building -2 | : | |
| | Ground floor | : | 186.20 Sq mtrs |
| | First floor | | 739.40 Sq mtrs |
| | Second floor | | 739.40 Sq mtrs |
| | Third floor | | 739.40 Sq mtrs |



| | | | |
|-----|---|---|--------------------------|
| | Total built up area | : | 2404.4 Sqmtrs |
| 09. | <u>Surrounding properties:-</u> | | |
| | Building -1 | : | |
| | East (front) | : | 09.00 mtrs Approach road |
| | West (rear) | : | 07.00 mtrs road |
| | North (side) | : | Ganesh temple |
| | South (side) | : | School building |
| | Building -2 | : | |
| | East (front) | : | 09.00 mtrs Approach road |
| | West (rear) | : | 07.00 mtrs road |
| | North (side) | : | School building |
| | South (side) | : | 06.00 mtrs road |
| 10. | <u>Open space all around the building:-</u> | | |
| | Building -1 | : | |
| | East (front) | : | 06.00 mtrs |
| | West (rear) | : | 1.50 mtrs |
| | North (side) | : | Nil |
| | South (side) | : | 30.00 mtrs |
| | Building -2 | : | |
| | East (front) | : | 1.50 mtrs |
| | West (rear) | : | 1.50 mtrs |
| | North (side) | : | 30.00 m,trs |
| | South (side) | : | 01.00 mtrs |
| | Allowed setbacks (open space) should be maintained free from further obstruction / construction | | |

B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

| Sl. No. (1) | Details (02) | Existing (03) | Recommendations (04) | | | | | | | | | | | | | | | | | | | | |
|--------------------------|-------------------------------|---|----------------------|---|--------------------|--------------------|---------------------|---|----------------|-----------|-----------------|---|---------------|----------|------------------|---|----------------|-----------|--------------------------|---|--------|--------|----------|
| 01. | Accessibility to the Premises | The premises is accessible from 09.00 mtrs wide Road, located on eastern Side The Road is hardened to carry the weight of 45,000 kgs. | Adequate | | | | | | | | | | | | | | | | | | | | |
| 02. | Number of entrances | 04 | Adequate | | | | | | | | | | | | | | | | | | | | |
| 03. | Number of staircase | <table border="1"> <tr> <td>No. of staircases</td> <td>:</td> <td>02 in building - 1</td> <td>01 no building - 2</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>Each 1.60 mtrs</td> <td>1.60 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>Each 0.30mtrs</td> <td>0.30mtrs</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>Each 0.15 mtrs</td> <td>0.15 mtrs</td> </tr> <tr> <td>No. of risers per flight</td> <td>:</td> <td>15 nos</td> <td>12 nos</td> </tr> </table> | No. of staircases | : | 02 in building - 1 | 01 no building - 2 | Width of staircases | : | Each 1.60 mtrs | 1.60 mtrs | Width of treads | : | Each 0.30mtrs | 0.30mtrs | Height of risers | : | Each 0.15 mtrs | 0.15 mtrs | No. of risers per flight | : | 15 nos | 12 nos | Adequate |
| No. of staircases | : | 02 in building - 1 | 01 no building - 2 | | | | | | | | | | | | | | | | | | | | |
| Width of staircases | : | Each 1.60 mtrs | 1.60 mtrs | | | | | | | | | | | | | | | | | | | | |
| Width of treads | : | Each 0.30mtrs | 0.30mtrs | | | | | | | | | | | | | | | | | | | | |
| Height of risers | : | Each 0.15 mtrs | 0.15 mtrs | | | | | | | | | | | | | | | | | | | | |
| No. of risers per flight | : | 15 nos | 12 nos | | | | | | | | | | | | | | | | | | | | |



| | | | | | | |
|-----|---|--|---|-----------|-----------|---|
| | | Height of handrails | : | 0.90 mtrs | 0.90 mtrs | |
| 04. | Portable extinguishers | Provided 06 nos of ABC type extinguisher of 6 kg capacity and 01 nos of 4.5 kgs capacity Co2 type extinguisher in the building -1 & 03 nos of ABC type extinguisher of 6 kg capacity and 01 nos of 4.5 kgs capacity Co2 type extinguisher in the building -1 | | | | complied |
| 05. | Hose reel hose system | Provided 02 hose reel hose of 19mm size and of adequate length to reach the farthest point of each floor, with a shut off branch.in building 1 & Provided 01 hose reel hose of 19mm size and of adequate length to reach the farthest point of each floor, with a shut off branch.in building 2 | | | | complied They are not under installation |
| 06. | Automatic sprinkler system | Not required | | | | Not required |
| 07 | At the terrace tank level with minimum pressure of 3.5 kg/cm ² . | 01 submergible pump of 900 lmp capacity is provided in building -1 & 01 booster pump of 450 lpm is provided in building -2 | | | | complied |
| 08. | Diesel generator | Diesel generator of 30 KVA capacity to supply alternative power supply is provided | | | | complied |
| 09 | Terrace tank | 01 underground tank of 20,000 ltrs capacity is provided in building -1 & 10000 ltrs capacity terrace tank is provided in building - 2 | | | | complied |
| 10. | Escape routes | Provided Directions in which the students and faculty should have to move in the event of any emergency have to be indicated in the corridor/passage on each floor as a guide during evacuation | | | | complied |
| 11. | Fire order (Fire safety plans) | Provided Notice boards indicating the details of action to be taken in case of any emergency with telephone numbers of davanagere Fire station i.e. 08192-258101 101,112, and nearby ambulance service and police station | | | | complied |
| 12 | No smoking board | displayed | | | | complied |
| 13 | Fire Siren | Installed | | | | complied |
| 14. | Nominate one Fire Nodal Officer | -- | | | | Not complied A fire nodal officer shall be nominated either from teaching or non teaching staff. |



| | | | |
|-----|---|--------------|---|
| 15 | Fire fighting training | Not imparted | At-least 40% of Teaching and non Teaching staff should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or Regional Training centre |
| 16. | <p><u>Fire precautionary measures :-</u></p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should not be stored in the building.</p> <p>E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon`ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.</p> | | |

Under above the circumstances the Karnataka Fire & Emergency Service Department is Issuing '**Fire Safety Recommendation**' to "Bapuji higher primary English school" door no : 33058, 1/A, MCC "B" ,Davanagere city, Davanagere Tq , Davanagere District Subject to condition and compliance of the above recommendations in coloumn-4 of series-B within 3 months and compliance to the undersigned.

This '**Fire Safety Recommendation**' is valid for only one year from the date of issue and it is renewable.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of fire and life safety will have to be complied with mandatory

Yours faithfully



[Handwritten Signature] 26/03/24
 District Fire Officer
 Karnataka Fire & Emergency Service
 Davanagere District.

[Handwritten Signature]
 PRINCIPAL
 Bapuji Higher Primary English
 School, MCC. 'B' Block,
 DAVANAGERE-577 004.